

Title

List of Tables

1	Statewide benchmarks for General 1200-A permits.	3
---	--	---

1 Monitoring

Monitoring will document compliance with permit conditions.

1.1 Storm waters benchmarks

Benchmarks included in the 1200-A permit assist permit holders in determining if the implementation of their SWPCP is reducing pollutant concentrations to below levels of concern.

Statewide benchmarks are summarized in Table 1. These are general benchmarks for facilities in Oregon not discharging mine dewatering.

1.2 Something else

Blah. Blah. Blah.

Table 1: Statewide benchmarks for General 1200-A permits.

Parameter	Benchmark
pH	5.5–9.0 Std Units
Total suspended solids	100 mg/L
Settleable solids	0.2 mg/L
Total oil & grease	10 mg/L